

Figure: 30 TAC §290.45(j)

Alternative Recreational Vehicle Park Connection Equivalency Values.

<u>Average Daily Demand (gallons per day per recreational vehicle site)</u>	<u>Alternative Recreational Vehicle Park Connection Equivalency¹</u>
<u>40.6 and higher</u>	<u>8</u>
<u>36.1 to 40.5</u>	<u>8.9</u>
<u>31.6 to 36.0</u>	<u>10.0</u>
<u>27.1 to 31.5</u>	<u>11.4</u>
<u>22.6 to 27.0</u>	<u>13.3</u>
<u>18.1 to 22.5</u>	<u>16.0</u>
<u>13.6 to 18.0</u>	<u>20.0</u>
<u>9.1 to 13.5</u>	<u>26.7</u>
<u>4.6 to 9.0</u>	<u>40.0</u>
<u>0.1 to 4.5</u>	<u>80.0</u>

¹The calculated connection count for the recreational vehicle park must be at least 1.0.