

Figure: 16 TAC §25.510(b)(5)

$$POF = \left[1 - \frac{\text{Total Evaluated Period Intervals}}{\text{Total Period Intervals}} \right] \times 100.$$

“Total period intervals” is equal to the total number of intervals in the evaluation period. “Total evaluated period intervals” is equal to the total number of intervals in the evaluation period that the generation resource was not in a planned outage.