

Figure: 26[25] TAC §510.131(f)[§134.131(f)]

[TABLE (6)]

STATION OUTLETS FOR OXYGEN, VACUUM, AND MEDICAL AIR SYSTEMS

Location	Number of Outlets*	
	Oxygen	Vacuum
Patient rooms	1	1
Examination/Treatment rooms	1	1
Isolation room	1	1
Emergency care secure holding area	1	1
Emergency care exam/treatment room	1	1

* Number of outlets indicated is required per each bed location or treatment unit.