

Figure: 30 TAC §30.350(e)

<u>Permitted Daily Average Flow</u>	<u>Category</u>
<u>No Discharge Treatment Systems</u>	
<u>All flows with a disposal system other than a subsurface area drip dispersal system</u>	<u>D</u>
<u>All flows with subsurface area drip dispersal systems</u>	<u>C</u>
<u>Pond Systems Preceded by Imhoff Tanks, Primary Clarifiers, or Facultative Lagoons</u>	
<u>1.0 million gallons per day (MGD) or less</u>	<u>D</u>
<u>Greater than 1.0 MGD</u>	<u>C</u>
<u>Activated Sludge- Extended Aeration Mode and Oxidation Ditch System</u>	
<u>0.10 MGD or less</u>	<u>D</u>
<u>Greater than 0.10 MGD to 1.0 MGD</u>	<u>C</u>
<u>Greater than 1.0 MGD to 10.0 MGD</u>	<u>B</u>
<u>Greater than 10.0 MGD</u>	<u>A</u>
<u>Activated Sludge- Modes Other than Extended Aeration</u>	
<u>0.050 MGD or less</u>	<u>D</u>
<u>Greater than 0.050 MGD to 1.0 MGD</u>	<u>C</u>
<u>Greater than 1.0 MGD to 10.0 MGD</u>	<u>B</u>
<u>Greater than 10.0 MGD</u>	<u>A</u>
<u>Trickling Filter, Rotating Biological Contactor, or Other Fixed Film Processes</u>	
<u>0.50 MGD or less</u>	<u>D</u>
<u>Greater than 0.50 MGD to 2.0 MGD</u>	<u>C</u>
<u>Greater than 2.0 MGD to 10.0 MGD</u>	<u>B</u>
<u>Greater than 10.0 MGD</u>	<u>A</u>